


Explosion area  
corresponding TRBS 2152-2  
Preliminary zoning



Zone 0  
Zone 1  
Zone 2

Emptying cabinet when emptying the slop container  
Emptying rate approx. 120m<sup>3</sup> / h  
Storage medium Jet-A1  
According to TRGS 509  
The result is a radius Ra = 1m  
Technically tight coupling of the filling hose from the tank car  
Zone 1 = Ra = 1m around the hose coupling to the floor

Phase V - Functional Tender

				Kunde / client	
				Lux-Airport s.a.	
				Projekt / project	
				Luxembourg Airport New Aviation Fuel Facilities	
				Société de l'Aéroport de Luxembourg S.A.	
				Benennung / title	
				Explosion area	
				Unit 2 - Road Briger Receipt Area	
				Zeichn. Nr. / draw. no.	
				2020-PJ-285-I-021	
				Blatt / sheet	
				4	
				Blatt / sheet	
				5	

CAD  
Copyright reserved

Grossmann  
Group  
Ingenieurbüro Großmann KG  
Wiesensteiger Str. 6  
73342 Bad Ditzingen-Gosbach  
Tel. +49 (0) 7335 961 1-0  
Fax +49 (0) 7335 961 15-25  
www.grossmann-germany.com  
Germany