


- Untis
- 1 -High Pressure Pipeline Reception Area
 - 2 -Road Bridger Reception Area
 - 3 - Fuel Farm
 - 4 - Fuel Pumpstation
 - 5 -Fuel Charging (Loading Area), with Into-plane Maintenance and Test Area
 - 6 - Hydrant - System
 - 7 - Connecting Pipelines
 - 8 -Diesel + AdBlue Station
 - 9 - Fire extinguishing system

Comment

1. No external hazardous zone when valve chamber covers are closed

2. No external hazardous zone when pit box is closed

3. Hydrant zone when in use.
see drawing Nr.: 2020-PJ-285-I-22_1/2



Phase V - Functional Tender